

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY  
CONDITION CERTIFICATE

No. 1302

Date 28/07/2025

It is certified that an inspection team headed by Rahul Kumar E.E (P.H.D Buxar) (Name of officer with designation) from P.H. Division Buxar (P.H.D) (Name of Department/ office) inspected the Foundation school, Gurdas Mathia, Itarsi Road Sonhaila, Buxar (Name and Address of the School) on 26-07-2025 and found that the Foundation school, Gurdas Mathia (Name of school) has safe drinking water facilities for the student and members of staff of the institution and is maintain the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/U.T.Govt.

The above valid for a period of six month.

Signature with seal:.....

Name Rahul Kumar  
Designation Executive Engineer  
P.H. DIVISION, BUXAR

To

Principal,  
Foundation school, Gurdas  
Mathia, Itarsi Road, Sonhaila, Buxar  
(Name & Address of institution)

**Government of Bihar**

Public Health Engineering Department

Water Quality Test Report

Division Name: Buxar

District :Buxar

Sample collected by , Foundation School, Itarhi Road, Buxar staff.

Date 25/07/2025

Sl. No.	Block	Location of Source	Parameters													Remarks		
			pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	Alka.	Fe	NO <sub>3</sub>	SO <sub>4</sub>	F	As	Total Coli.	
2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	
1	Buxar	Foundation School, Gurudas Mathia, Itarhi Road Sonhaila, Buxar	7.4	1	477	310	150	48	24.48	70	164	0.2	BDL	15	0.3	0.002	Negative	Fit for Drinking
		UNIT		NTU	µmho/cm	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l		
		Desirable Limit*	6.5-8.5	1		500	200	75	30	250	200	0.3	45	200	1	0.01		
		max.permissible limit	NR	5		2000	600	200	100	1000	600	1.0	NR	400	1.5	NR		

\* BDL - Below detection limit.

\* NR - Not recorded.

P.H. Division, Buxar

Executive Engineer  
P.H. Division, Buxar

25/07/2025